

293

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/GH/NDZ/2022/ 487

Dated 20/06/2022

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub: Regarding renewal of Fire Safety Certificate in respect of **M/S Seema Lodge** located at **3745, Churiwalan, Chawri Bazar, Delhi- 06.**

Sir,

With reference to online application I.D. no. 2021083019556 dated 31.08.2021 & letter no. nil dated 01.06.2022 on the subject cited above, it is informed that the guest house was inspected by Assistant Divisional Officer (SPM) from this department on 13.06.2022 in the presence Mohd. Akhlaq (Manager) and it was observed that building is comprised of Ground + 03 upper floors. During inspection, following shortcomings were observed:

1. Fire check door not provided, required as per Gazette Notification dated 27.05.2019.
2. CO detectors with panel and alarm not provided, required as per Gazette Notification dated 27.05.2019.
3. Public address system not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(Dr. S.K. Tomar)
Dy. Chief Fire Officer o/c
Tel: 011-23412025

Copy to:-

The Manager, M/S Seema Lodge at 3745, Churiwalan, Chawri Bazar, Delhi- 06.

84
16/6