

459

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/NDZ/2022/64/467

Dated: 14/06/2022

To

The Manager
M/S **Su Shree Continental Dx. Guest House**,
3198/XV/1, Opp. MCD Dispensary,
Gali Sangtrashan, Pahar Ganj, New Delhi.

Sub: Regarding issuance of FSC in r/o M/S **Su Shree Continental Dx. Guest House**, located at
3198/XV/1, Opp. MCD Dispensary, Gali Sangtrashan, Pahar Ganj, New Delhi.

Sir,

This has reference to online ID No. 2022040605724 dated 06.04.2022, on the subject cited above. In this connection it is to inform you that the site was inspected by the officers concerned department on 06/06/2022 in the presence of **Manager** and observed Fire check doors are not provided at each floor as per gazette notification dated 27.05.2019.

In view of above, Fire Safety Certificate cannot be issued. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully



(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to :-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi