

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001


आजादी का
अमृत महोत्सव
16/06/2022

No. F6/DFS/MS/Hospital/2022/NDZ/ 1426

Dated:

To,

Dr. Ashok Singh (Director),
Shri Ram Singh Hospital, B-25-26, 26 A,
Swaran Cinema Road, East Krishna Nagar Delhi -110051.

**Sub:- Fire Safety inspection in r/o Shri Ram Singh Hospital & Heart Institute B-25-26, 26 A,
Swaran Cinema Road, East Krishna Nagar Delhi -110051.**

Sir,

With reference to your Email id-srshhi@gmail.com dated 05/05/2022 on this subject noted above. In this connection it is to inform you that the premises was visited by the officers concerned of this department on 01/06/2022 in the presence of Sh. B.K. Mishra (Admin). The hospital building comprised of basement, ground plus two upper floors. During the course of inspection following observations were made:-

1. An overhead water tank having capacity 20,000 litter is provided against requirement of 25000 Ltr .
2. A fire pimp of 250 liters per minute discharge is provided against requirement of 900 lit./min.
3. The staircases of width 2.00 meter which has been provided in the building, shall be continuous and fulfill the requirements as mentioned in National Building Code Part-IV.
4. Sprinklers required to be extended in the left out areas (rooms) of basement.
5. Fire safety measures viz. hose reel hose, internal hydrants were also found non functional.
6. Few Rooms on terrace (Tin Shed) were also found constructed, to be removed or sanctioned drawing to be submitted.

In view of above, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier. The Licensing Authority / Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


16/06/22

(Dr. S.K. Tomar)
Dy. Chief Fire Officer

Copy for information & taking necessary action please:-

1. Directorate of Health Services, F-17, Karkardooma, Delhi-110032.