



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F.6 DFS/MS/Banquet/WZ/2022/94

Dated: - 14 06 2022

To,

The Dy. Health Officer, Keshav Puram Zone, NDMC. Public Health Department, A-1 Block Keshav Puram Zone, Delhi.

Sub:- <u>Renewal of Fire Safety Certificate in respect of M/s. The Heritage Grand Banquet, located</u> <u>at Plot No.- B/12, Lawrence Road Industrial Area, New Delhi- 35.</u>

Sir,

This has reference to your online application received through MHA portal vide ID-2022052210913, on the subject cited above. In this connection it is to inform you that the above said assembly building has been inspected by the officer concerned of this department on 07.06.2022 in presence of Sh. Sandeep Madan (owner), to check the fire safety arrangements already provided in the building.

During the course of inspection, it was observed that the banquet hall building is comprised of two tier basement, ground and two upper floors. Fire safety arrangements such as fire extinguishers, hose reel, wet riser system, detection system, sprinkler system, MOEFA, fire pump & terrace pump etc. found provided. However, following shortcomings have been observed:

- 1. Fire/smoke check doors found removed at some places in basement & upper floors.
- 2. Sprinkler system shall be extended in left out areas.
- 3. Detection system shall be extended in left out areas.
- 4. Exit signage's removed at some places.

In view of above shortcomings, the application for renewal of fire safety certificate is not considered at this stage & rejected. The occupancy of the building/premises in absence of requisite fire safety measures shall be at the risk and liabilities of the owner/occupier. Λ

Yours faithfully,

(Dharampal Bhardwaj) Dy. Chief Fire Officer (West Zone)

Copy to:-

1. Sh. Sandeep Madan, M/s. The Heritage Grand Banquet, Plot Nol- B/12, Lawrence Road Industrial Area, New Delhi- 35,