



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. F6/DFS/MS/School/2022/NDZI/329

Dated: 20/06/2022

To,

The Principal,
EDMC Primary School,
Khera, G.T Road, (Gen)
Shahdara North, Delhi 110095.

Sub:- Regarding Issuance Fire Safety Certificate of R/o EDMC Primary School at Khera G.T Road (Gen.) Shahdara North, Delhi-110095 .

Sir,

This is in reference to your letter no. EDMC/EE(E)-I/SHN/2021-22/D-40 dated-02/05/2022 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned school from fire safety point of view in presence of Mr. Subhash Chandra (Principal) of the School on 31/05/2021. During the course of inspection, the following points / shortcomings were noticed in the building which is comprised of ground plus two upper floors.

1. A fire pump having 220 liters per minute provided in place of 450 LPM Output at 40 meters head as required.

In view of above, the building can not be considered for issue of Fire Safety Certificate at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully,

(Atul Garg)
Director

Copy to:-

- 1) The Director of Education, MCD
Udyog Sadan, Plot No. 419, FIE,
Patparganj, Delhi 92
- 2) The Ex. Eng. (Elect.)-II,
Shahdara (North)Zone,
MCD, Office of Executive Engineer (Elect)-II,
MCD Zonal Office Buildings, Keshav Chowk,
G.T. Road, Near Shyam Lal College.