

C-39 P1

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No: F.6/DFS/MS/School/SZ/2022/ 332

Dated: 20/06/2022

To

The Principle,
Govt. Sarvodaya Bal Vidyalaya,
West Patel Nagar, New Delhi- 110008.


Sub.: - Regarding renewal of Fire Safety Certificate in r/o Govt. Sarvodaya Bal Vidyalaya,
West Patel Nagar, New Delhi-110008.

Sir,

Please refer to your letter No. GSBV/WPN/2022/70 dated 24.05.2022, on the subject cited above, in this connection, it is to inform you that the aforesaid school building have been inspected by the officer concerned of this department in presence of Sh. P.S. Gupta, Estate Manager of the School, on 08.06.2022 to check the status of the shortcomings pointed out by this department vide letter No. F.6/DFS/MS/School/SZ/2018/11812 dated 04.05.2018. But no improvement was observed as seen during the course of inspection.

In view of the above, 'Fire Safety Certificate' cannot be renewal at this stage. In the absence of fire safety certificate this school is not safe from fire safety point of view. You are requested to rectify the above-mentioned fire safety arrangements under intimation to this department.

Yours faithfully


(Sunil Chaudhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service



Copy to: -

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

(with a request to take further action as school does not have fire NOC)

-2
C-30

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUATERS: DELHI FIRE SERVICE: NEW DELHI-110001

No: F.6/DFS/MS/School/SZ/2018/ 1812

Dated: - 04/05/18

To,

The Head of the School,
Govt. Sarvodaya Bal Vidyalaya,
West Patel Nagar, New Delhi- 110008.

Sub.: Regarding renewal of Fire Safety Certificate in r/o Govt. Sarvodaya Bal Vidyalaya, West Patel Nagar, New Delhi- 110008.

Sir,

Please refer to your letter No. SBV/WPN/137 dated 16.03.2018 on the subject cited above. In this connection, it is to inform you that the aforesaid school building have been inspected by the officer concerned of this department in the presence of Sh. Harikishan, principal of the school, on 10/04/2018 to check the status of the shortcomings already pointed out by this department vide letter no. F.6/DFS/MS/School/2015/1677 dated 29.07.2015, and status is as under: -

Sr. No.	Shortcomings	Status
1.	The first aid hose reels are provided but not functional	Not provided
2.	Down comer system is provided but not functional	Not Provided
3.	Fire pump of 450 LPM discharge with 30 mts head is provided but not functional.	Not Provided
4.	The overhead water storage tank of 10000 lts cap is provided but empty.	Not Provided

In view of the above, 'Fire Safety Certificate' cannot be renewed at this stage. You are requested to rectify the above-mentioned fire safety arrangements under intimation to this department.


Yours faithfully


(VIPEN KENTAL)
CHIEF FIRE OFFICER

Copy to: -

1. The Director of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi

for information please


26/4/18