

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001**

No.F.6/DFS/MS/SZ/2022/School/334

Dated: 20/06/2022

To,

Mrs. Rashmi Shukla (Principal),
Kendriya Vidhalaya,
Sector – 08, SPG Complex,
Dwarka, New Delhi 110077

Subject: Renewal of Fire Safety Certificate in r/o Kendriya Vidhalaya Located at Sector – 08,
SPG Complex, Dwarka, New Delhi 110077.

Sir,

Please refer to your letter no. F//KVSPG/2022-23/29 Dated 06-05-2022 on the subject mentioned above. In this connection it is to inform you that the premises was inspected by the officer concerned from this department on 28/05/2022 in the presence of Mrs. Rashmi Shukla (Principal) for fire safety point of view.

The following shortcoming was observed during the time of inspection:-

- 1: Hose reel hose found nonfunctional & nozzles found missing at some places.
2. Terrace pump found nonfunctional.

You are requested to comply the above mentioned shortcomings under intimation to this department for further necessary action.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,



(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service.

Copy to; - Directorate of Education Old Secretariat Delhi – 110054