

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/School/NDZ/2022/331

Dated: 20/06/2022

To

The Principal,  
Rabea Girls Public School,  
Gali Qasimjan, Ballimaran, Delhi- 110006.

**Sub:** Issuance of Fire Safety Certificate to **Rabea Girls Public School, Gali Qasimjan, Ballimaran, Delhi- 110006.**

Sir,

This has reference to your letter no.nil dated 11.05.2022 on the subject cited above. In this regard it is to inform you that Delhi Fire Service has already communicated shortcoming vide letter no.F6/DFS/MS/2018/1133 dated 21.03.2018 (copy enclosed). It has not been complied by the management till date.

In view of above, the FSC of the premises cannot be considered at this stage. You are suggested to rectify the above said shortcoming under the intimation to this department for further action.

Yours faithfully,

  
17/06/22

**(Dr. S. K. Tomar)**  
Dy. Chief Fire officer  
Delhi Fire Service  
Tel: 011 - 23412025

**Copy to:-**

The Director of Education, Old Secretariat, Delhi- 110054.

o/c  
8  
16/6

C-41

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI -110001**

No.F6/DFS/MS/2018 / 1133

Dated 21/3/18

To

The Principal,  
Rabea Girls Public School  
Katra Dina Beg, Lal Kuan, Delhi -110006.

Sub:- Regarding grant of FSC in r/o Rabea Girls Public School Katra Dina Beg, Lal Kuan, Delhi -110006.

Sir,

Please refer to your letter No. Nil. dated 06/03/18 on the subject cited above. In this regard, it is to inform you that school premises has been inspected by the officer concerned of this department in the presence of Dr. Nahid R. Usmani of school on 06/03/18.

During inspection, following shortcomings were observed:-

1. Road width is less than required width 6 mtr. Hence building is not accessible to fire engines.

Keeping in view the above, "Fire Safety Certificate" to the above said building can not be considered at this stage.

Yours faithfully,



(Sunil Chowdhary)  
Dy. Chief Fire Officer  
Delhi Fire Service

Copy to :-

The Director of Education,  
Old Secretariat, Delhi-110054.

2c  
13/3/18