

C 120

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/GH/NDZ/ 490

Dated: 23/06/2022

To,

The Manager,
M/S Sahara International Deluxe,
3162/63/34/35, Sangatrashan, Pahar Ganj,
New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S The Sahara International Deluxe,
Guest House 3162/63/34/35, Sangatrashan, Pahar Ganj, New Delhi.

Sir,

This has reference to your mail id no.<rarora777@yahoo.com> dated 09/06/22, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 16/06/2022 in the presence of **Manager** and observed that Fire Check Door on the staircase are not installed as per gazette notification 27.05.2019.

Therefore, you are requested to submit the compliance as per gazette notification 27.05.2019 for further consideration in the matter.

Yours faithfully,


21/6/22

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to

1. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony, New Delhi.