

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/School/2022/SZ/ 338

Dated: 22/06/2022

To

The Principal,
Bluebells School International,
Kailash, New Delhi 110048

Sub: Regarding issuance of FSC in r/o Bluebells School International Kailash, New Delhi 110048

Sir,

This has reference to with received through Outdoor diary no 1540 dated 19/06/2022 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 08.06.2022 in the presence of Mrs. Manju Sethi to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Sprinkler system provided in the basement but not in functional.
2. The wet riser / Hose reel fire main water supply pipe line shall be of not less than 100mm diameter in size.
3. Electrician Fire Pump capacity 1620 LPM, Diesel Engine Pump 1620 LPM and Jockey Pump 180 LPM not provided. Terrace level Fire Pump capacity of 900 LPM not provided.
4. Exit signage found removed in some places.
5. The wooden partition and erected rooms shall be removed. Moreover these shall not be used.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/Management of School. The Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

Copy to:-

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054