

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

NO.F6/DFS/MS/2022/WZ/ 342

Date: 23/06/2022

To,

The Principal,  
Chhotu Ram Rural Institute of Technology,  
Kanjhawala (Ghevra), Delhi-110081.

**Sub: Regarding Renewal of Fire Safety Certificate in r/o Chhotu Ram Rural Institute of Technology located at Kanjhawala (Ghevra), Delhi-110081.**

Sir,

This has the reference to your letter received via outdoor diary no. 1902 dated 30/05/2022 on the subject sited above, it is submitted that the aforesaid building was visited by officer concerned of this department on 09.06.2022 in presence of Sh. Sombir Deswal (Principal). Your request for renewal of Fire Safety Certificate is rejected due to following shortcoming/observations at the time of inspection:-

1. Fire Extinguishers provided but not Functional.
2. First Aid Hose Reel provided but not functional.
3. Internal Hydrant provided but not functional.
4. Terrace Pump & Jockey pump provided but not functional.

You are requested to apply again after compliance of the above mentioned shortcoming/observations.

Yours Faithfully

(Dharampal Bhardwaj)

Dy. Chief Fire Officer

West Zone

oll R

Copy to:

1. Director, Training & Technical Education, Muni Maya Ram Marg, Near T.V Tower, Pitampura, Delhi-88.