

976

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/GH/NDZ/ 478

Dated:-14/06/2022

To,

The Manager,
M/S Delhi Regency Guest House,
8183-85, A.K. Road,
Pahar Ganj, New Delhi.

Sub: Renewal of fire safety certificate in r/o M/S Delhi Regency Guest House at 8183-85, A.K. Road, Pahar Ganj, New Delhi.

Sir,

This has reference to your online ID no. **2022051810584 dated 18.05.2022** on the subject cited above. In this regard, it is to inform you that the site was visited by the officers concerned of this department on dated 10.06.2022 in presence of manager and observed that the CO detectors and smoke management system at each floor are not installed in the guest house as per gazette notification 27.05.2019. Further, no guest room is shown in the building plan at ground floor, whereas in application form one guest room is filled, same may be clarified.

Therefore, you are requested to rectify the same & submit the compliance as per gazette notification 27.05.2019 for further consideration in the matter.

Yours faithfully,


14/6/22

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:

1. The Addl. Commissioner of police (Lic.), Ist Floor, Defense Colony Police Station , New Delhi.