

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F6/DFS/MS/School/WZ/2022/344

Dated: 23/06/2022

To,

The HOS,
Sarvodaya Kanya Vidyalaya,
Mundka, New Delhi-110041.

Sub. :-Regarding renewal/issuance of Fire Safety Certificate in r/o Govt. Sarvodaya Kanya Vidyalaya Located at Mundka, Delhi-110041.

Sir,

Please refer to your email dated 17.05.2022 on the subject cited above. In this connection, it is to inform you that the said School building has been inspected by the officer concerned of this department on 27.05.2022 in the presence of Sh. Rajeev Malik (Estate Manager) to see compliance of the shortcomings communicated vide this department letter no. F6/DFS/MS/School/WZ/2021/14 dated 05.01.2021.

During the course of inspection, it has been observed that the Management has rectified some of the shortcomings, the status is under:-

<u>S. no.</u>	<u>Shortcomings</u>	<u>Status</u>
1.	First aid hose reel is provided in blocks but all found non-functional	Rectified but Old block hose reel found non-functional yet
2.	Overhead water storage tank capacity 10000 ltrs. provided on old block found empty.	Rectified
3.	Terrace pump found removed on old block. In block A & B, terrace pump is provided but found non-functional	Rectified
4.	Exit Signages found missing at various places in all block.	Rectified
5.	Some fire extinguishers checked/tested were not found in working condition	Rectified

In addition to the above, Hose reel hose found non functional in M. P. Hall.

In view of the above shortcoming, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Education Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Dharampal Bhardwaj)
Dy. Chief Fire Office
(West Zone)

Copy to:-

1. The Director, Directorate of Education Old Secretariat Delhi – 110054