

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F-6/DFS/MS/School/2022/341  
To

Dated 23/06/2022

The Principal  
Govt. Sarvodaya Kanya Vidyalaya  
Vijay Nagar, Delhi-110042.

**Sub:** - Regarding issuance of fire safety certificate in r/o Govt. Sarvodaya Kanya Vidyalaya (School Id No. 1309167 ) located at Vijay Nagar, Delhi-110042.

Sir,

Please refer to your letter received through email I.D dated 28.04.2022 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 28.05.2022 to verify the fire safety measures issued vide NBC Part 4 and observed that the school premise is comprised of Single block, ground and 03 upper floors. At the time of inspection Smt. Alka Rani, Principal was also present at site. During the course of inspection observations/ shortcomings made are as under:-

1. Fire extinguisher provided in the building were checked and found short in no total 8nos ABC type required for school building.
2. Hose reel hose provided but found not functional at the time of inspection.
3. Hydrant provided but found not functional and some hoses found missing.
4. Terrace level fire fighting pump capacity of 450lpm but found not functional.
5. Terrace level fire water tank capacity of 10,000ltrs provided and found empty.
6. Exit signage found removed at some places.

Yours faithfully

(Dharampal Bhardwaj)  
Dy.Chief Fire Officer  
Ph:-011-23414250

Copy to: -

1. The Director of Education, Government of N.C.T of Delhi. Old Sectt. Delhi.