

4/12

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/EH/2022/NDZ/ 407

Dated: 14/06/2022

To

Sh. Naveen Gupta,
M/s Jubilant Food works Ltd.,
1st Floor, Shop No. SF,15, 16 & 16A,
Plot No. 9D, Aditya Mega Mall,
C.B.D. Shahdara, New Delhi-110032.

Sub.:- Fire Safety inspection in r/o M/s Jubilant Food works Ltd., 1st Floor, Shop No. SF,15, 16 & 16A, Plot No. 9D, Aditya Mega Mall, C.B.D. Shahdara, New Delhi-110032.

Sir,

With reference to your letter No. Nil dated 02/05/2022 on the subject noted above. In this connection, it is to inform you that the premises was visited by the officer concerned of this department on 20/05/2022. During the inspection it was observed that Eating house is not having independent Fire Safety Arrangement viz. it is common for mall. ~~The~~ Aditya Mega Mall in which this eating house is situated is not in possession of valid Fire Certificate (FSC of this mall was not renewed after year 2006).

In view of above, the application for issuance Fire Safety Certificate is rejected.

the occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier. The Licensing Authority / Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


14/6/22

(Dr. S.K. Tomer)
Dy. Chief Fire Officer.

ok e.

Copy for information & necessary action:-

1. Dy. Health officer, Shahdara South Zone, C-86, Mandawali Main Road, Joshi Colony, I.P. Extension, Delhi-110092.
2. Addl. Commissioner of Police (Lic.), 1st Floor Police Station, Defence Colony, New Delhi-24.
3. Executive Engineer (Building) MCD H.Q., 419, Udyog Sadan, Patparganj Ind. Area, New Delhi-110092.