

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

C59

No.F6/DFS/MS/GH/NDZ/ 2022/482

Dated:-17.06/2022

To,

The Manager,
M/S K.V.M International,
4196, Bhagwati Bhawan,
Pahar Ganj, New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S K.V.M International, 4196, Bhagwati Bhawan, Pahar Ganj, New Delhi. ID No. 2022050309218 dated 03/05/22.

Sir,

This has a reference to on line ID No. 2022050309218 dated 03/05/22. on the subject cited above. In this regard, it is to inform you that the site was visited by the officers concerned of this department on dated 13.06.22 in presence of **Mr. Ashok** and observed that the Smoke Management system & CO detector are not provided as per Gazette Notification dated 27.05.2019.

Therefore, you are requested to comply the same for further consideration in the matter.

Yours faithfully,


16/6/22

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

✓

Copy to :-

1. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.