

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F.6/DFS/MS/School/2022/NDZ/1356

Dated - 24/06/2022

To,

The Ex. Engineer (Elect.)-II
Shahdara (North Zone)
EDMC Office of the Executive Engineer (Elect.)-II
MCD Zonal Office Building, Keshav Chowk,
G.T. Road, Near Shyam Lal Collage,
Delhi-110053


Subject: - Regarding Issuance of Fire Safety Certificate in r/o Nigam Pratibha Vidyalaya at Mohanpuri, Shahdara North, Delhi-110053.

Sir,

With reference to your letter No. EDMC/EE(E)-I/SHN/2021-2022/D-40 dated 02/05/2022 on the subject cited above. In this connection this is to inform you that, the inspection of the above said premises was carried out by the officer concerned of this department on dated 01/06/2022. During the inspection it was observed that the shortcomings as communicated earlier vide letter No. F.6/DFS/MS/School/2022/NDZ/119 dated 16/03/2022 have not been complied as yet (The copy of the same is enclosed for reference).

In view of the above Fire Safety Certificate cannot be considered at this stage. You are once again requested to rectify the said shortcoming under intimation to this office for further consideration in the matter.

Yours faithfully


23/6/22

(Dr. S. K. Tomar)
Dy. Chief Fire Officer

o/c
e.

Copy to:-

1. The Director of Education, MCD
Dr. S.P. Mukherjee Civic Center, JLN Marg,
New Delhi-110002
2. The Principal
Nigam Pratibha Vidyalaya at Mohanpuri, Shahdara North, Delhi-110053.

C-19

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F6/DFS/MS/School/2022/NDZ/ 119

Dated 16/03/2022

To,

The Principal,
Nigam Pratibha Vidyalaya,
Mohanpuri, Shahdara North,
Delhi 110053

Sub:- Regarding Issuance Fire Safety Certificate in r/o Nigam Pratibha Vidyalaya located Mohanpuri, Shahdara North, Delhi-110053.

Sir,

This is in reference to your letter No. EDMC/MP II/2022/01 dated 09/02/2022 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned Nigam Pratibha Vidyalaya from fire safety point of view in presence of Mr. Ravi Kiran, HOS of the School. The building comprise of ground plus two upper floors. Following shortcomings were observed during the time of inspection.

1. Only 10 fire extinguishers provided in place of 19 fire extinguishers as required.
2. First-Aid hose reels provided but not functional.
3. Terrace pump having 450 LPM output at 40 meter head provided but not functional.
4. Exit Signage were not provided.

In view of above, the building can not be considered for issue of Fire Safety Certificate at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully



(Dr. S.K. Tomar)
Dy. Chief Fire Officer

c/c 

Copy to:-

The Director of Education, EDMC
Udyog Sadan, Plot No. 419, FIE,
Patparganj, Delhi 92