



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

NO. F6/DFS/MS/CGHS/SZ/2021/1501

DATED: 23/06/2022

To,

✓
Sh. Narendra Jha (President),
Janaki CGHS Ltd,
Plot No. 07, Sector- 22, Dwarka,
New Delhi-110075

Subject: - Renewal of Fire safety Certificate from fire safety & means of escape point of view in r/o Janaki CGHS Ltd, Located at Plot No. 07, Sector- 22, Dwarka, New Delhi-110075.

Sir,

This is in reference to your Form J & K Dated 24/05/2022 on the subject cited above. In this connection it is to inform to you that the above said residential building has been inspected by the officer concerned of this department on 07/06/2022 in the presence of Sh. Narendra Jha (President).

During the course of inspection followings shortcoming are observed:-

1. The internal road found blocked & encroached.
2. Fire check doors found removed in basement.
3. Hose reel hoses & hydrants found damaged/ nonfunctional.
4. The pumps at ground level found nonfunctional in auto mode.
5. Exit signage's found removed at some places.
6. Communication in lift car found removed
7. The basement must be used as per BBL 1983.

You are requested to comply the abovementioned shortcomings under intimation with this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,


(Atul Garg)
(Director)
Delhi Fire Service

Copy to:- The Joint Director, DDA, Vikas Sadan, INA, New Delhi.