

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No.F6/DFS/MS/School/NDZ/2022/367

Dated:- 29/06/2022

To

The Principal,
St. Andrews Scots Sr. Sec. School,
9th Avenue Extension, Patparganj, Delhi-92.

Sub: Regarding Renewal of FSC in r/o St. Andrews Scots Sr. Sec. School located at 9th Avenue Extension, Patparganj, Delhi-92.

Sir,

This has reference to your letter no. nil dated 28/05/2022 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 16/06/2022 in the presence of Mr. K.L Malhotra (Incharge) and the following shortcomings were observed :-

1. Hose reel/Hydrant not covering whole area and needs to be extended in ground floor Hall.
2. Exit Signage found removed.
3. Pump is not on auto mode.
4. Temporary bio-lab structure at terrace to be removed.

In view of above, the Fire Safety Certificate cannot be considered at this stage. You are requested to rectify the above mentioned shortcomings under the intimation to this department for further necessary action in this regard.

Yours faithfully


29/6/22

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service
ML

Copy to:-

The Director (Education),
D-Block, Anand Vihar, Delhi - 91.