



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No.F6/DFS/MS/Hospital/2022/WZ/ 1567

Dated: 29/06/2022

To,

Sh. R. S. Bhatia, (Chairman)  
Bhati Global Hospital & Endosurgery Institute,  
305-307-308, Ambica Vihar,  
Paschim Vihar, New Delhi-110087.

**Subj:- Regarding renewal of Fire Safety Certificate in r/o Bhati Global Hospital & Endosurgery Institute Located at 305-307-308, Ambica Vihar, Paschim Vihar, New Delhi-110087**

Sir,


Please refer to your letter no. nil dated 21.05.2022 on the subject cited above. In this connection, it is to inform you that the above said building were re-inspected by the officers concerned of this department on 10.06.2022 in the presence of Sh. Manoj (MR Executive).

During inspection, it has been observed that the above said building is comprised of Basement + Ground + 03 Upper Floors served with 02 staircases. The Fire safety arrangement such as fire extinguisher, first aid hose reel, automatic fire detection & alarming system, MOEFA, PA System, Internal Hydrant, Yard hydrant, fire pumps, overhead water tank & Underground water tank etc. Found provided. However, the following points have been noticed as shortcomings:-

1. Width of alternate staircase found reduced to 0.85 m at Ground floor & 3<sup>rd</sup> floor to terrace floor width of against width of 2.0 m.
2. Fire Check Door found removed at basement floor.
3. Smoke Management Systems found removed.
4. Automatic fire detection & alarming system is provided but not extended at some areas & found non-functional.
5. MOEFA is provided but found non-functional.
6. PA system is provided but found non-functional.
7. Automatic Sprinkler System is provided at basement but not extended at some left out areas.
8. Exit signages are inadequate.
9. Pressurization of lift shaft found non-functional.
10. Lift lobby is not segregated with fire check door at each floor.
11. Alternate staircase (Iron staircase) covered with fibre sheet to be replaced with non- flammable material.
12. In alternate staircase (Iron staircase) wooden board provided on the steps is to be removed.
13. In Main entries of hospital, electrical panels & stabilizer installed/provided in the alternate staircase, is to be removed at safer place.

In view of the above shortcomings, renewal of FSC is not considered & rejected. You are requested to submit point wise compliance & till such time occupancy of the building/premises in absence of requisite fire safety arrangements at your own risk and responsibility.

Yours faithfully,

  
(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
(West Zone)

Copy to:-

1. The Director of Health Services. Govt. of NCT of Delhi. F-17 Karkarduma. Delhi-32.