

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI <u>HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001</u>

ebb

No.F6/DFS/MS/GH/NDZ/ 2022 499

Dated:-7.9.106 /2022

To,

The Manager, M/S Hotel Shelton Guest House, 5043, Main Bazar, Pahar Ganj, New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Hotel Shelton Guest House, 5043, Main Bazar, Pahar Ganj, New Delhi

Sir,

This has a reference to your letter no. <u>Nil</u> dated 18.05.22. on the subject cited above. In this regard, it is to inform you that the site was visited by the officers concerned of this department on dated 24.06.22 in presence of **Manager** and observed that the Fire Check Door on the staircase are not installed as per gazette notification 27.05.2019.

Therefore, you are requested to comply the same for further consideration in the matter.

Yours faithfully,

(Dr. S.K.Tomar) Dy. Chief Fire Officer Delhi Fire Service

Copy to :-

1. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.