

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F.6/DFS/MS/NDZ/2022/ 1575

Dated:- 28/06/2022

To

Executive Engineer (E),
Delhi Electrical Division-202,
I.G.I. Stadium, New Delhi-110002.

Sub: Regarding inspection for renewal of FSC in r/o Indira Gandhi Stadium complex at Indraprastha Estate, New Delhi.

Sir,

This has reference to your letter No.24(2)EE(E)/DED-202/2022/475 dated 28/05/22 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 17/06/2022 in the presence of Mr. Kamal Kumar, JE(E) & Mr. Das AE(E) and the following shortcomings were observed:-

1. Some of the Fire extinguishers found empty.
2. Hose reel nozzle found missing at some places.
3. Detectors found nonfunctional.
4. Hose & Hose coupling from hose boxes and branches found missing.
5. MOEFA found nonfunctional and some found broken.
6. PA system sound having poor audio quality.
7. Pumps were not on auto mode.
8. Wherever seats in a row are more than 14 nos. need to be removed
9. Door closers at fire check door needs to be provided wherever not provided.
10. Under ground tank is not accessible for fire tender.

In view of above Fire Safety Certificate cannot be considered at this stage. Therefore, you are requested to rectify above mentioned shortcomings at the earliest. Further, the occupancy of building /premises in absence of requisite fire life safety arrangements shall be at risk and liability of the owner /occupier. The Statutory /licensing authority may take suitable action as deemed fit.

Yours faithfully,


(Atul Garg)
DIRECTOR

Delhi Fire Service

Copy to:-

1. Administrator, Sport Authority of India, IGI Stadium Complex, New Delhi.
2. Addl. C.P./Lic , First floor , Defence Colony Police Station, New Delhi : with a request not to book /allow function in the stadium till it will provide required fire safety protection.