

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F.6/DFS/MS/2022/NDZ/ 1573

Dated 29/6/2022

To,

The Executive Engineer,  
CPWD, Safdarjung Hospital Electrical Division,  
New Delhi – 110002.

**Sub:- Regarding renewal of FSC in r/o Manak Bhawan 9, Bahadur Shah Zafar Marg, New Delhi – 110002.**

Sir,

This has reference to your e-mail e-mail < eesjhed@gmail.com dated 24.05.2022 letter no. 19(1)/DB/SHED/2022-2023/741 dated 23.05.22 on the subject cited above, it is to inform that the site was inspected by the officers concerned of this department on 13/06/2022 in the presence of Sh. Mukesh Meena & Miss Pallavi Gupta, AE (E) CPWD and the following shortcomings were observed: -

1. Electric shaft/openings are not sealed properly.
2. Smoke management system in basement found nonfunctional.
3. Sprinklers are not provided in one room at basement.
4. Diesel pump not in auto mode provision.

In view of above shortcomings, request for renewal of fire NOC is rejected. The occupancy of building /premises, in absence requisite fire & life safety arrangements, shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit.

Yours faithfully

  
(Atul Garg)  
DIRECTOR  
Delhi Fire Service

Copy to

1. Sh A.K.Das, Head, PMWD, BIS Manak Bhawan, 09, Bahadur Shah Zafar Marg, New Delhi.