

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/SCHOOL/WZ/2022/365

Dated: 30/06/2022

To

The Principal,
Sarvodaya Kanya Vidyalaya,
School No. 01, Chand Nagar,
New Delhi-110018.

Subject: - Regarding renewal of Fire Safety Certificate in r/o Sarvodaya Kanya Vidyalaya, School No. 01 (old Block) Located at Chand Nagar, New Delhi-110052 (School ID-1514011).

Sir,

Please refer to Email dated 09/06/2022 on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officer concerned of this department on 17/06/2022 in presence of Sh. Neeti Bharara Oberoi (Principal) to check the shortcomings already issued by this department vide letter no. F6/DFS/MS/School/MN/2022/34 dated 27/01/2022.

The Status of the Shortcomings are as under:-

S. no.	Shortcomings	Status
1.	First Aid Hose reel are provided but not functional.	Not Rectified
2.	Terrace Fire Pump of 450 lpm is provided but not on auto mode.	Not Rectified
3.	Exit signages are not provided.	Not Rectified

In view of above Shortcomings the application for renewal of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety Arrangements Shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy To: -

1. The Director, Directorate of Education, old secretariat, Delhi.

1/2
26/6/2022