

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

No.F6/DFS/MS/School/NDZ/2021/363

Dated: -28/06/2022

To

The Principal,
The Bengali Senior Secondary School,
22A, Shyam Nath Marg, Delhi -110054.

Sub:- Regarding issuance of Fire Safety Certificate in r/o **The Bengali Senior Secondary School, 22A, Shyam Nath Marg, Delhi-54.**

Sir,

This has reference to letter no. BSSS/14/609 dated 31.05.2022 received in this department, on the subject cited above. In this connection, this is to inform you that the school building was inspected by officer concerned from this department on 17.06.2022 in the presence of Sh. N.C. Bandhu (Account Section). During the inspection following shortcomings were observed:-

1. First Aid Hose reel found not functional.
2. Fire pump not in auto start mode.
3. Exit signages not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


27/6/22

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Tel: 011-23412025

Copy to:-

The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.

o/l
27/6