



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75  
आजादी  
अमृत महोत्सव

No.F6/DFS/MS/WZ/2022/ 1572

Dated: - 29/06/2022

To,

Sh. Mukesh Taneja,  
M/s. Trela Footwear Export Pvt. Ltd.,  
Plot No. F-1, Udyog Nagar,  
Rohtak Road, New Delhi-110041.

**Subject: Regarding renewal of Fire Safety Certificate in r/o M/s. Trela Footwear Export Pvt. Ltd. Located at Plot no. F-1, Udyog Nagar, Rohtak road, Delhi-110041.**


Sir,

This has reference to your Form "J" dated 19.05.2022 on the subject cited above. In this connection, it is to inform you that the above said building has been inspected by the officer concerned of this department from fire safety point of view on 13.06.2022 in the presence of Sh. Mukesh Taneja (Owner). During inspection, it has been observed that the said building is comprised of Basement + Ground Floor served with 02 staircases. The Fire safety arrangement such as fire extinguisher, first aid hose reel hose, overhead water storage tank & underground water storage tank etc found provided. However, the following points have been noticed as shortcomings:-

1. The Exit door is 1 m instead of required 1.2 m width.
2. Hose reel is provided but not functional.
3. Fire / Smoke Check Door are not provided.
4. Smoke Management System is not provided at basement.
5. Overhead water storage tank is 10,000 ltrs capacity instead of required 20,000 ltrs. capacity for fire fighting.

In view of the above shortcomings, renewal of FSC is not considered & rejected. You are requested to submit point wise compliance & till such time occupancy of the building/premises in absence of requisite fire safety arrangements at your own risk and responsibility.

Yours faithfully,

  
(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
(West Zone)