

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F.6/DFS/MS/NDZ/2022/16/5

Dated 01.07/2022

To,

Smt. Darshita Aggrawal,  
Aggrawal House,  
4/14 A, Asaf Ali Road,  
New Delhi.

**Sub:- Regarding renewal of FSC in r/o of Aggrawal House at 4/14 A Asaf Ali Road,  
New Delhi.**

Sir,

This has reference to your letter no. nil dated nil on the subject cited above. In this regard, it is to inform that the site was inspected by the officers concerned of this department on 22/06/2022 in the presence of yourself and observed that Detectors found nonfunctional.

In view of above shortcoming, request for renewal of fire FSC is rejected. Therefore you are requested to rectify the above shortcomings at the earliest under intimation to this department. Further, the occupancy of building /premises, in absence requisite fire & life safety arrangements, shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit.

Yours faithfully,

(Ajay Garg)  
DIRECTOR

Delhi Fire Service

Copy to:

1. The Commissioner, MCD, Civic Centre, New Delhi.