

C 39

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/GH/NDZ/ 2022/503

Dated:-29/06/2022

To,

The Manager,
Brahmputra Guest House,
1225-26, Sangatrashan Bazar,
Pahar Ganj, New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Brahmputra Guest House located at 1225-26, Sangatrashan Bazar, Pahar Ganj, New Delhi. Online id. 2022052110824 dated 21.05.22

Sir,

This has reference to on line ID No. 2022052110824 dated 21.05.22 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 26/06/2022 in the presence of **Manager** and following shortcomings were observed:

1. Smoke management system is not installed as per Gazette Notification dated 27.05.2019.
2. Hose reel & pump found nonfunctional and pump is also not in auto mode provision.
3. Building is comprised of ground and four upper floor and 02 staff room at terrace, whereas building plan uploaded on the site of ground and three upper floors only.
4. An affidavit/undertaking regarding not to use upper floors is also not submitted.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage. Therefore, you are requested to submit the compliance of the shortcomings for further consideration in the matter.

Yours faithfully,



(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service



Copy to:-

1. The Addl. Commissioner of Police (Lic.), First floor, PS Defence Colony, New Delhi.