

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/EH/2022/SZ/442

Dated 01/07/2022

To
The Dy. Health Officer, SDMC
Public Health Officer,
Aurobindo Marg, South Zone,
Green Park, Delhi 110016

Sub: - Regarding issuance of fire safety certificate in r/o M/s DEJA BREW (Unit Of Hops And Beans Pvt Ltd) M-20 GF & Mezzanine, M Block Market, GK-2, Delhi 110048.

Sir,
This has reference to your MHA Portal ID No. 20220451410247 dated 14/05/2022 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 16.06.2022 in the presence of Mr. Dharmender (Manager) to verify the fire safety measures installed in the building and observed that restaurant running at GF, FF, SF & Third Floor of the building. During inspection, following points were observed:

- 1 There are two staircase having width of 1.50 mtr & 1.0 mtr against the required with of 1.50 mtr each respectively.
- 2 Pumping arrangements are not on auto mode.
- 3 Underground tank for firefighting capacity 50,000 ltrs provided against the required capacity of 1, 00,000 ltrs.
- 4 Exit Signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-
1. The Joint Commissioner of Police, Lic/Branch, 1st Floor, P S Defence Colony, New Delhi -110049. For taking necessary action on the matter.