

C72

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/GH/SZ/2021/517

Dated: 04/07/2022

To

The Owner/Occupier,  
M/s. Hotel Kama Palace, 9A/34,  
Channa Market, WEA, Karol Bagh, New Delhi- 110005.

Sub:- Regarding renewal of Fire Safety Certificate in respect of M/s. M/s. Hotel Kama Palace, 9A/34, Channa Market, WEA, Karol Bagh, New Delhi- 110005.

Sir,


Please refer to your Online Application No. 2022050209152 dated 07.05.2022, on the subject cited above. In this connection, it is to inform you that the aforesaid guest house has been inspected by the officer concerned of this department on 22.06.2021 in the presence of Sh. Ramesh Kumar (Manager), to check the functionability of fire safety arrangements already provided in the guest house building.

During the course of inspection, it was observed that the said guest house is comprised of basement, ground plus three upper floors. Guest house served by 01 staircases having width 1.25 mts. from ground to terrace and 01 staircase having width 1.30 mts from basement to ground floor. Fire safety arrangements such as overhead water tank, first aid hose reel, MOEFA, fire extinguishers, D.G.Set etc. found provided. However the following shortcomings were observed as per the notification No. F.5(1897/AD/LB/2016/4053-65 dated 27.05.2019 in respect of existing building :-

1. Fire Check doors found not provided.

In view of the above as per the notification No. F.5(1897/AD/LB/2016/4053-65 dated 27.05.2019. The FSC issued vide letter no. F6/DFS/MS/GH/SZ/2021/152 dated 23.03.2021 stands null and void. In the absence of fire safety certificate this guest house is not safe from fire safety point of view. You are advised to rectify the above mentioned shortcomings and apply a fresh on MHA portal for further necessary action in this matter.

Yours faithfully,



(Sunil Chaudhary)  
Dy. Chief Fire Officer (SZ)  
Delhi Fire Service

Copy to :-

1. The Joint Commissioner of Police (Lic.), Police Station, Defence Colony, 1st floor, New Delhi.