

C.50

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/GH/NDZ/ 2022/512

Dated: 01.07/2022

To,

The Manager,
M/S J.J. International,
265 to 70, Mantola, Pahar Ganj,
New Delhi

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S J.J. International, 265 to 70, Mantola, Pahar Ganj, New Delhi.

Sir,

This has a reference to your Online id no.2022051310234 dated 14.05.22, on the subject cited above. In this regard, it is to inform you that the site was visited by the officer concerned of this department on dated 27.06.22 in presence of **Manager** and observed that the CO detectors are not installed as per gazette notification 27.05.2019.

Therefore, you are requested to comply the same for further consideration in the matter.

Yours faithfully,


30/6/22

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service



Copy to :-

1. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.