

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/GH/NDZ/ 2022/501

Dated: 29/06/2022

To,

The Manager,
Roma Villa Guest House ,
4055, Kaseruwalan, Pahar Ganj,
New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Roma Villa Guest House, at 4055, Kaseruwalan, Pahar Ganj, New Delhi. ID No. 2022051109933 dated 11.05.22.


Sir,

This has reference to on line 2022051109933 dated 11.05.22, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 22/06/2022 in the presence of **Mr. Rajesh** and following shortcomings were observed: -

1. Smoke Management system is not provided as per Gazette Notification dated 27.05.2019.
2. CO type detectors are not provided as per Gazette Notification dated 27.05.2019.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage. Therefore, you are requested to submit the compliance of the same for further consideration in the matter.

Yours faithfully,


27/6/22

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

✓

Copy to :-

1. The Addl. Commissioner of Police (Lic.), First floor, PS Defence Colony, New Delhi.