

C37

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/GH/NDZ/ 2022 /513

Dated:-01/07/2022

To,

The Manager,
M/S Vintage Inn, Guest House,
871, Gali Chandi Wali, Pahar Ganj,
New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Vintage Inn, Guest House, 871, Gali Chandi Wali, Pahar Ganj, New Delhi.

Sir,


This has a reference to your Online id no.2022053011622 dated 30.05.2022, on the subject cited above. In this regard, it is to inform you that the site was visited by the officers concerned of this department on dated 28.06.22 in presence of **Manager** and observed that the smoke management system are not installed as per gazette notification 27.05.2019.

Therefore, you are requested to comply the same for further consideration in the matter.

Yours faithfully,


30/6/22

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service


30/6

Copy to :-

1. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.