

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F.6/DFS/MS/School/2022/NDZ/358

Dated - 24/06/2022

To,

The Ex. Engineer (Elect.)-II
Shahdara (North Zone)
EDMC Office of the Executive Engineer (Elect.)-II
MCD Zonal Office Building, Keshav Chowk,
G.T. Road, Near Shyam Lal Collage,
Delhi-110053

Subject: - Regarding Issuance of Fire Safety Certificate in r/o EDMC Primary School at Jagat Puri (Gen.), Mandoli Road, Shahdara, Delhi-110093.

Sir,

With reference to your letter No. EDMC/EE(E)-I/SHN/2021-2022/D-40 dated 02/05/2022 on the subject cited above. In this connection this is to inform you that, the inspection of the above said premises was carried out by the officer concerned of this department on dated 01/06/2022. During the inspection it was observed that the shortcomings as communicated earlier vide letter No. F.6/DFS/MS/School/2021/NDZ/657 dated 16/12/2021 have not been complied as yet (The copy of the same is enclosed for reference).

In view of the above Fire Safety Certificate cannot be considered at this stage. You are once again requested to rectify the said shortcoming under intimation to this office for further consideration in the matter.

Yours faithfully


23/6/22

(Dr. S. K. Tomar)
Dy. Chief Fire Officer

Copy to:-

1. The Director of Education, MCD
Dr. S.P. Mukherjee Civic Center, JLN Marg,
New Delhi-110002
2. The Principal
EDMC Primary School at Jagat Puri (Gen.), Mandoli Road, Shahdara, Delhi-110093.

G11

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6/DFS/MS/School/2021/NDZ/ 857

Dated: 16/12/2021

To,

The Principal,
EDMC Primary School,
Jagat Puri (General), Mandoli Road,
Shahdara, Delhi-110093

Subject:- Regarding issuance of Fire Safety Certificate.

Sir,

With reference to your email Id eee2shahnorthzone@gmail.com dated 23/11/2021 on the subject cited above, it is informed that officer concerned of this department inspected the school from fire safety point of view in presence of Ms. Chetna Rani, Incharge & Sh. Gajender Singh J.E. (Elect.), Shahdara North Zone on dated 04/12/2021. The school building comprises of ground plus two upper floors. During the course of inspection following observations was made:-

1. One staircase of width 1.50 meter or an additional staircase of 0.75 meter width is not provided.

In view of the above, the school building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours faithfully,


(Atul Garg)
Director

Copy to:-

1. The Director of Education, EDMC
Udyog Sadan, Plot No. 419, FIE,
Patparganj Industrial Area, Delhi-110092
2. The Ex. Engr. (Elect.)-II,
Shahdara North Zone,
EDMC, Office of Executive Engineer (Elect.)-II,
MCD Zonal Office Building, Keshav Chowk,
G.T. Road, Near Shyam Lal College,
Delhi-110053