

C 21

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No.F-6/DFS/MS/School/2022/ 371

Dated 04/07/2022

To

The Principal
M.C.Primary Girls School,
Nathupura-I, Delhi-110084.

Sub: Regarding issuance of fire safety certificate in r/o M.C. Primary Girls School located at Nathupura-I, Delhi-110084.

Sir,

Please refer to your letter received online e-mail dated 02.06.2022 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 17.06.2022 to verify the fire safety measures installed as per Director of Education circular and building was comprised of 02 blocks, ground plus 02 upper floors each only. At the time of inspection Sh. Parmod Sharma (Guard) was also present at site. During the course of inspection observations/ shortcomings made are as under:-

1. The approach road width is provided 04m against the requirement of 06m for movement of fire engine in case of emergency fires.
2. Fire extinguishers provided but found not functional.
3. Hose reel hose provided but not functional.
4. Terrace level fire pumps capacity 450lpm provided but not functional.
5. Overhead fire water tank capacity 10,000ltr provided empty.
6. Exit signage's not provided at strategic location in the building.

Keeping in view of above, fire safety certificate cannot be considered at this stage.

Yours faithfully,



(Atul Garg)
Director

Ph:-011-23414000

ojc op

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi-110054.