

215



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F.6/DFS/MS/School/2022/NDZ/ 369

Dated 04/07/2022

To,

The Principal,
MCD Primary School
Shastri Park, H-Block,
Delhi- 110053.

Sub:- Regarding Issuance Fire Safety Certificate r/o MCD Primary School located at Shastri Park, H-Block, Delhi- 110053.

Sir,

This is in reference to your letter No. EDMC/EE(E) -I/SHN/2021-22/D-40 dated 02/05/2022 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned School from fire safety point of view in presence of Mr. Virender Singh, Principal of the school. The building comprised of ground plus two upper floors. Following shortcomings were observed during the time of inspection.

1. First-Aid hose reels not provided.
2. Fire pump having capacity 450 lpm output 40 meter head not provided.
3. Over head water storage tank capacity 10,000 liters for firefighting not provided.
4. Exit signs not provided.

In view of the above, the building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours faithfully

(Arul Garg)
Director

ole
2.
Delhi Fire Service

Copy to:-

The Director of Education, MCD
15th Floor, E- Block, Dr. S.P. Mukherjee Civic Center, JLN Marg,
New Delhi-110002