

c8



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F.6/DFS/MS/School/2022/NDZ/ 368

Dated 04/07/2022

To,

The Principal,
MCD Primary School
Mansarovar Park, Shahdara,
Delhi-110032

Sub:- Regarding Issuance Fire Safety Certificate r/o MCD Primary School located at Mansarovar Park, Shahdara, Delhi-110032

Sir,

This is in reference to your letter No. EDMC/EE(E) -I/SHN/2021-22/D-40 dated 02/05/2022 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned School from fire safety point of view in presence of Mr. Sushil Kumar, Principal of the School. The building comprised of ground plus one upper floor. Following shortcomings were observed during the time of inspection.

1. The width of staircase shall be 1.50 meter or an additional staircase of 0.75 meter shall be provided.

In view of the above, the building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours faithfully,

A handwritten signature in blue ink, appearing to read "Atul Garg".

(Atul Garg)
Director

ole
2-
Delhi Fire Service

Copy to:-

The Director of Education, MCD
15th Floor, E- Block, Dr. S.P. Mukherjee Civic Center, JLN Marg,
New Delhi-110002