



No. F6 /DFS/MS/Mercantile/SZ/2022 /1645

Dated: 06/07/2022

To

M/s Fast Track Realcon, Living Style Mall
Pocket-6, Main Kalindi Kunj Road,
Jasola, New Delhi.

Sub: - Regarding grant of Fire Safety Certificate in r/o **M/s Fast Track Realcon, Living Style Mall located at Pocket-6, Main Kalindi Kunj Road, Jasola, New Delhi.**

Sir,

With reference to Outdoor Diary no. 2159 dated 03.06.2022 on the subject cited above, it is informed that the said building was inspected by Assistant Divisional Officer (M. Road) from this department on 13.06.2022 in the presence of Manager and it was observed that the building is comprised of Basement + Ground + 03 upper floors. During the inspection the following shortcomings were observed: -

1. A ventilation system in the basement is not functional.
2. Hose reel, Internal hydrants, Automatic Sprinkler system, Pumping arrangements were found non functional.
3. Exit door (main & alternate) shall have minimum width of 1.50 meters each.

The management may be requested comply the above shortcomings within 90 days from date of issue.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

Copy to:-

1. The Executive Engineer (Building), South DMC, 9th floor, Dr. SPM Civic Centre, JLN Marg, New Delhi.