



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव

No.F6/DFS/MS/GH/SZ/2022/ 497

Dated: 27/06/2022

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station,
Defence Colony, New Delhi.

Sub:- Regarding renewal of Fire Safety Certificate in r/o **M/s Amby Inn Guest House located at M-13, Lajpat Nagar-II, New Delhi-24.**


Sir,

With reference to the online application no. 2022060111846 dated 02.06.2022 on the subject cited above, it is informed that the building was inspected by Assistant Divisional Officer (M. Road) from this department on 17.06.2022 in the presence of Mr. Rajesh (Owner) and it was observed that the building is comprised of Basement + Ground + 03 upper floors. During the inspection following shortcomings were observed:-

1. A ventilation system in the common areas to be made.
2. Segregation of common staircase to be done at ground floor.
3. Hose reel, Automatic Sprinkler system, Pumping arrangements were found non functional.
4. Temporary construction on roof to be removed.
5. Fire tank to be segregated.
6. Combustible furnishing in common areas to be removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Sunil Chawdhary)
Dy. Chief Fire Officer
Delhi Fire Service

etc. [Signature]
28/6

Copy to:-

M/s Amby Inn Guest House located at M-13, Lajpat Nagar-II, New Delhi-24.