

C. 29

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/GH/NDZ/2022/496

Dated: 23/06/2022

To

M/s Ashoka Guest House,
1969-71, Katra Lochaoo Singh,
Fountain, Chandni Chowk, Delhi.

Sub: Regarding issue of Fire Safety Certificate (FSC) in r/o M/s Ashoka Guest House at 1969-71, Katra Lochaoo Singh, Fountain, Chandni Chowk, Delhi.

Sir,

This is in reference to email dated 26.05.2022 on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on dated 13.06.2022 and observed that the shortcomings intimated vide letter of even No.F6/DFS/MS/GH/NDZ/2022/374 dated 19/05/2022 have not been complied yet. (Copy enclosed for ready reference).

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

Encl: As above.


21/6/22

(Dr. S. K Tomar)
Dy. Chief Fire Officer
Tel:011-23412025

Copy to:-

The Joint Commissioner of Police (Licensing), 1st Floor, Police Station Defence Colony, New Delhi.

o/l
21/6

C 72

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/GH/NDZ/2022/ 374

Dated: 19/05/2022

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub: Regarding renewal of Fire Safety Certificate in respect of **M/s Ashoka Guest House, located at 1969-71, Katra Lochao Singh, Fountain, Chandani Chowk, Delhi.**

Sir,

With reference to online application I.D. no. 2022041507109 dated 15.04.2022 on the subject cited above, it is informed that the guest house was inspected by Assistant Divisional Officer (SPM) from this department on 10.05.2022 in the presence of Mr. Arvind (Manager) and it was observed that building is comprised of Ground + 04 upper floors. During inspection, following shortcomings were observed:

1. Fire check door not provided required as per gazette notification dated 27.05.2019.
2. CO detectors not provided required as per gazette notification dated 27.05.2019.
3. Fire extinguishers found non functional.
4. Fire pump found not in auto start mode.
5. Exit signage not provided.
6. Public address system not provided.
7. Occupancy at fourth floor is not allowed as per gazette notification dated 27.05.2019.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(Dr. S.K. Tomar)

Dy. Chief Fire Officer

Tel: 011-23412025 olc

Copy to:-

M/S Ashoka Guest House, located at 1969-71, Katra Lochao Singh, Fountain, Chandani Chowk,
Delhi

82
185