

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001**

NO. F6/DFS/MS/SZ/2022/24/426

DATED: 24/06/2022

To,

The Joint Commissioner of Police (Lic),
1st Floor, Licensing Unit, Police Station,
Defence Colony, New Delhi

Subject: - Issuance of Fire safety Certificate from fire safety & means of escape point of view in r/o M/s Café Di Millano A unit of 3 Amigos Located at Ground Floor, plot no-97 Block-B Pocket -10 Sector-13 Dwarka, New Delhi - 110078.

Sir,

This is in reference to your letter no. 2022051310195 Dated 16/05/2022 on the subject cited above. In this connection it is to inform to you that the above said building has been inspected by the officer concerned of this department on 13/06/2022.

During the course of inspection followings shortcoming have been observed:-

1. The width of one exit doors is 142 cm is provided against required two of 1.5 m width.
2. MOEFA & PA system found not provided.
3. Hose Reels & Internal Hydrants are found not provided
4. Exit signages are found not provided.
5. One Terrace pump of 450 LPM found not provided.
6. Overhead water storage tank of 20000 litres capacity found not provided. The tank must be exclusively for fire fighting.

In view of the above, fire safety certificate cannot be renewed. You are advised to rectify the said shortcomings under intimation to this department for taking further necessary action.

Yours faithfully,


(Atul Garg)
Director
Delhi Fire Service

Copy to:-

The Manager M/s Café Di Millano A unit of 3 Amigos Located at Ground Floor, plot no-97 Block-B Pocket -10 Sector-13 Dwarka, New Delhi - 110078