



C-66

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001**

NO. F6/DFS/MS/SZ/2022/ School/372

DATED: 17/2022

To,

Sh. R.B Gupta (President)
Ferry Education Socirty,
C-331, Saraswati Vihar, Pitampura,
New Delhi - 110034

Subject: - Renewal of Fire safety Certificate from fire safety & means of escape point of view
in r/o J M International School, Sector - 6, Dwarka, New Delhi - 110075

Sir,

Please refer to your letter no FES/FIRE/22 Dated 07/06/2022 on the subject cited above. In this connection it is to inform you that the above said building has been visited by the officer concerned of this department on 22/06/2022 in the presence of Sh. R.B Gupta President.

During the course of inspection followings shortcoming have been observed

1. Exit Doors of the stairs are found locked at terrace level. All the Exits must be clear from any obstruction and free from lock and key.
2. The Passage lead stairs must be kept free from any obstruction.
3. Terrace pumps of 900 lpm & 180 lpm found nonfunctional in auto mode
4. Exit signage's found removed at some places.
5. Basement must be used as per BBL1983.

In view of the above, fire safety certificate cannot be renewed. You are advised to rectify the said shortcomings under intimation to this department for taking further necessary action.

Yours faithfully,

(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.
2. The Principal J M International School, Sector - 6, Dwarka, New Delhi - 110075

150/22
17/22