

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No.F6/DFS/MS/WZ/2022/ 1656

Dated: - 27/07/2022

To,

Sh. Adash Jain,
M/s. Lal Chand Jain,
Plot no. H-53, Udyog Nagar,
Rohtak Road, Delhi-110041.

Subject: Regarding renewal of Fire Safety Certificate in r/o M/s. Lal Chand Lal Located at Plot no. H-53, Udyog Nagar, Rohtak road, Delhi-110041.


Sir,


This has reference to your Form "J" dated 17.05.2022 on the subject cited above. In this connection, it is to inform you that the above said building has been inspected by the officer concerned of this department from fire safety point of view on 17.06.2022 in the presence of Sh. Adash Jain (Owner). During inspection, it has been observed that the said building is comprised of Ground + Mezz. Floor + 01 Upper Floors served with 02 staircases. The Fire safety arrangement such as fire extinguisher etc found provided. However, the following points have been noticed as shortcomings:-

1. First aid hose reel hose found non-functional.
2. Overhead water storage tank found removed.
3. Automatic Sprinkler system found removed at basement.

In view of the above shortcomings, renewal of FSC is not considered & rejected. You are requested to submit point wise compliance & till such time occupancy of the building/premises in absence of requisite fire safety arrangements at your own risk and responsibility.

Yours faithfully,


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)


30/6/22