

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001**

NO. F6/DFS/MS/SZ/2022/ *Schnell/378*

DATED: *6/7/2022*

To,

The Principal <naveenps1993@gmail.com>
Naveen Public School,
Street No – 36, Sadh Nagar – II,
Palam Colony, New Delhi – 110045

Subject: - Issuance of Fire safety Certificate from fire safety & means of escape point of view in r/o Naveen Public School located at Street No – 36, Sadh Nagar – II, Palam Colony, New Delhi – 110045.

Sir,

Please refer to your Email Dated 06-06-2022 on the subject cited above. In this connection it is to inform you that the above said building has been visited by the officer concerned of this department on 21/06/2022 in the presence of Sh. Sunil Kumar Sachan (Manager) and found that one floor has been added in the building as the school building is now comprised of Ground plus two upper floors.

During the course of inspection followings shortcoming have been observed:-

1. Two stairs of 1.5 m width remotest to each other must be provided.
2. Width of class room doors found less than 1.2 m at 2nd floor.
3. Width of corridor/ exit passage must have clear width of 1.5 mtr
4. The Terrace pump of 450 lpm is found not provided.
5. Overhead water storage tank of 10000 ltrs capacity found not provided.
6. Exit signage found not provided.

In view of the above, fire safety certificate cannot be renewed. You are advised to rectify the said shortcomings under intimation to this department for taking further necessary action.

Yours faithfully,

(Signature)
(Atul Garg)
Director
Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.