



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/GH/SZ/2022/ 492

Dated: 23/06/2022

To

The Joint Commissioner of Police (Licensing),  
1<sup>st</sup> Floor, Police Station, Defence Colony,  
New Delhi.

**Ref:** Online application no. 2022060111854.

**Sub:** Regarding renewal of Fire Safety Certificate in respect of **M/s Rajdeep Palace Guest House located at 4-B, Bharat Nagar Market, New Friends Colony, New Delhi-25.**

Sir,

This has reference to the online application no. 2022060111854 dated 02.06.2022 on the subject cited above. On the scrutiny of the application it was observed that:

1. The plan uploaded alongwith the application does not bear signature and stamp of a registered architect.
2. Building plan shows a kitchen at 3<sup>rd</sup> floor. Kitchen is not permitted to operate in guest house occupancy.
3. Other details like height of the building, details of staircases etc. are not matching the records with this department.

In view of the above, the application bearing no. 2022060111854 is rejected. You are requested to re-apply with correct details a sanctioned building plan or 'as built' building plan signed & stamped by a registered architect and owner.

Yours faithfully,

**(Sunil Chawdhary)**  
Dy. Chief Fire Officer  
Delhi Fire Service

dlc [Signature] 20/6