GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No- F.6/DFS/MS/EH/2022/ 430

Dated 27 / 06/2022

To

Col. Rajender Dadhwal Bhalswa Golf Course Near Bhalswa Lake, Delhi-110042.

Sub: - Regarding issuance of fire safety certificate in r/o M/s The Dinners Club Cafeteria Block at Bhalswa Golf Course Near Bhalswa Lake, Delhi-110042.

Sir,

This has reference to your online mha portal I'd No.2022050609555 dated 11.05.2022 on the subject cited above. In this connection this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 13.06.2022 in the presence of Col. Rajender Dadhwal to verify the fire safety arrangements as stipulated in NBC Part 4 and as well installed in the building. During the course of inspection it has observed that the building/ premise is comprised of ground & first floor only. Your request for FSC is rejected under Rule 37 (3) due to following shortcomings.

- 1 Fire extinguisher provided in the building were checked and found not working at the time of inspection.
- 2 Hose reel hose provided but not functional.
- 3 Smoke detector provided but not functional.
- 4 Internal hydrants provided but not functional.
- 5 Terrace pumps capacity of 450lpm provided but not functional.
- 6 Terrace level fire water tank capacity of 10,000ltrs provided but found empty.
- 7 Exit signage's found removed at strategic location in the building.

Keeping in view of above Fire Safety Certificate cannot be considered at this stage. You may apply again on form 'I' as stipulated in sub rule (2) 35 of rules, DFS Rules 2010 after compliance of the shortcoming mention above. The link for forms is as under available on http://delhi.gov.in./wps/wcm/connect/doit fire/FIRE/Home/Forms.

Yours faithfully

(Dharampal Bhardwaj) Dy. Chief Fire Officer Ph: 011-23414250

oje &

Copy to:

 The Additional Commissioner of Police/Lic, 1st Floor, Police Station Defence Colony, New Delhi.