



C-8

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE**  
**NEW DELHI- 110 001**

No. F.6/DFS/MS/School/2022/NDZ/ 380

Dated 8/7/22

To,

The Ex. Engineer (Elect.)-II  
Shahdara (North Zone)  
EDMC Office of the Executive Engineer (Elect.)-II  
MCD Zonal Office Building, Keshav Chowk,  
G.T. Road, Near Shyam Lal Collage,  
Delhi-110053

**Subject:** - Regarding Issuance of Fire Safety Certificate in r/o EDMC Primary School at Nathu Colony, Shahdara, Delhi-110032.

Sir,

This is in reference to your letter No. EDMC/EE(E) -I/SHN/2021-22/D-40 dated 02/05/2022 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned School from fire safety point of view on dated 22/06/2022 in presence of Mrs. Rajni Tyagi Principal of the School. The building comprised of ground plus two upper floors. Following shortcomings were observed during the time of inspection.

1. One staircase of width 1.30 meter is provided against requirement of two staircase of width 1.50 meter.
2. First-Aid hose reels provided but not functional.
3. Fire pump having 450 LPM output with 40 meter head not provided.
4. Overhead water storage tank capacity 10,000 liters is not provided.
5. Exit signages were not provided.

In view of the above, the building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours faithfully

  
(Atul Garg)  
Director

o/c  
2  
Delhi Fire Service

Copy to:-

1. The Director of Education, MCD  
15<sup>th</sup> Floor, E- Block, Dr. S.P. Mukherjee Civic Center, JLN Marg,  
New Delhi-110002
2. MCD Primary School  
Nathu Colony, Shahdara, Delhi-110032