

c-3

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No. F6/DFS/MS/School/2022/ 378

Dated: 8/7/2022

To

Smt. Manju Soni,
HOS,
Jagat Vidhya Sanatan Dharm Girls Sr. Sec School,
D-2, Link Road, Karol Bagh, New Delhi -110005.

**Sub: Regarding issuance of FSC in r/o Jagat Vidhya Sanatan Dharam Girls Sr. Sec School
D-2, Link Road, Karol Bagh, New Delhi -110005.**

Sir,

This has reference to your letter no. P-1565 dated 27.04.2022 on the subject cited above. In this regard, it is to inform you that the site was visited by officer concerned of this department on 27.06.2022 in the presence of Smt. Manju Soni and following shortcomings are observed.

1. 02 nos Hose reel hose are not provided.
2. Overhead tank of 10,000 liter is not provided.
3. Pump of 450 LPM capacity is not provided.

In view of above, fire safety certificate (FSC) cannot be considered at this stage. Therefore, it is requested to rectify the above shortcomings at the earliest for further consideration in the matter inform to this department.

Encl: As above.

Yours faithfully,

(Atul Garg)

DIRECTOR
Delhi Fire Service

Copy to:-

1. The Director (Education), Govt. of NCT, Old Sectt. Delhi - 54.