

Don 12

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No. F6/DFS/MS/School/2022/ 397

Dated: 7/1/2022

To

The Assistant Engineer (Electrical)
Sub Div.-04 Education Electrical Edu. Div (N), PWD,
Room no. 03 first floor, plot no 41, Satguru Ramsingh Marg,
Rama Road, Zakhira, Delhi -110015.

Sub: Regarding issuance of FSC in r/o New SPS type additional class rooms at SKV Padam Nagar, New Delhi.

Sir,

This has reference to your e-mail id.< aepedsd4@gmail.com dated 18.05.2022 & letter no. 54(15)A.E.(E)-4/PWD/M-1/2021-22/118 dated 27.10.2021 on the subject cited above. In this regard, it is to inform you that the site was visited by officers concerned of this department on 16.06.2022 in the presence of Sh. Santosh Bish, Estate Officer and following shortcomings are observed.

1. Hose reel found nonfunctional & nozzles also found missing.
2. Pump not in auto mode provision.
3. Alternate exit of 1.5 meter is not provided in multipurpose hall.

Further, reply of earlier letter issued vide letter no.F6/DFS/MS/SCHOOL/2021/658 dated 16.12.2021 is still awaited.

In view of above, fire safety certificate (FSC) cannot be considered at this stage. Therefore, it is requested to rectify the above shortcomings at the earliest for further consideration in the matter inform to this department.

Encl: As above.

Yours faithfully,


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Principal, SKV Padam Nagar, New Delhi.
2. The Director (Education), Govt. of NCT, Old Sectt. Delhi - 54.