

C-75

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2022/ 395

Dated: 8/7/22

To,

The Principal,
Prince Public School,
Budh Vihar, Phase-II,
Delhi-86.

Sub: Issue of FSC in r/o Prince Public School, Budh Vihar, Phase-II, Delhi-86.


Sir,

Please refer your office letter No. PPS/22 dated 09.05.2022, received in this department vide O.D No. 1243 on dated 10.05.2022 on subject cited above. The premise was inspected by the concern nominated authority of this department on **21.06.2022**, in presence of **Mr. Sandeep Gulati (Principal)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Over Head fire water captive tank capacity found reduced to 8000 ltrs against the required capacity of 15,000ltrs.
2. Terrace Fire pump provided but not functional in Gr. + 01 building.
3. Additional construction found to be carried out on terrace of second floor and multipurpose hall found to be constructed on Gr. + 01 building.
4. The required exit signage is not provided.

Hence, you are thereby advice to refer two set of building plans drawn on scale of 1:100, duly marked with fire and life safety provision, through local authority under Section to 2(q) & Rule 34, for further consideration in this matter.

Yours faithfully


(Dhrampal Bhardwaj)
Dy. Chief Fire Officer
Tel; -01123414250

DL
24